

I am against ET Docket No 04-37. Studies conducted in Japan, Europe and the USA show that BPL causes serious interference to radio systems from 1.7 to 80 MHz. The NTIA Report 04-413 also states that interference is likely when BPL is within 460 Meters of a fixed amateur radio station. This will interfere with, if not incapacitate, my station for emergency communications and casual operating from 1.7 to 80 MHz. The local Power Company is not very cooperative in solving power line leakage problems and I believe that this situation will get much worse if BPL is utilized. Thank you for hearing my comments on this matter.